

Certificate of Compliance

Certificate: 1172047 (LR 37234-4)

Master Contract: 169993

Project: 1172047

Date Issued: April 4, 2001


Issued to: **TE-Contact AG**
Schonmattstrasse 6
CH-4153 Reinach
Switzerland
Attention: Mr. Dieter Schmid

The products listed below are eligible to bear the CSA Mark shown



Issued by:


J. Lam, C.E.T.

Authorized by: 
Brian Rossborough, P. Eng.
Operations Manager

PRODUCTS

CLASS 3211 03 - INDUSTRIAL CONTROL EQUIPMENT - Motor Controllers - Auxiliary Devices

Pushbutton Switches, Open type, Illuminated or non-illuminated for flush mounting, Series TH 4, Cat Nos 4... and Series TH 5, cat Nos 5...., rated B300 (5A), 300V ac and/or 5A, 125V dc, and/or 0.3A, 250V ac max, pilot light voltage 220V; Types 4000 and 4001, rated A300 (10A), 300V ac, max pilot light voltage 300V.

Pushbutton Switch Modules, single or double pole, open type, for mounting on illuminated or non-illuminated actuator units for flush mounting, Series TH 25, Cat Nos (2) 5..., rated 5A, 250V ac and/or 1A, 250V dc, max pilot lamp voltage 220V.

Pilot Lights, open type, for flush mounting, Series TH 4, Cat Nos 4...., Series TH 5, Cat Nos 5.... and Series TH 25, cat Nos (2)5...., max lamp voltage 220V; Types 4000 and 4001, max lamp voltage 300V.

Notes:

1. Open type devices are Certified as components for use in other Certified equipment where the suitability of the combination is to be determined by CSA International.
2. Cat Nos of Series TH 4, TH 5 and Th 25 are connected in same polarity per deck/module.
3. The type designation is completed with suffix numbers indicating type of operating means, number of contact units and on the mechanical details.

APPLICABLE REQUIREMENTS

CAN/CSA-C22.2 No. 14-95 - Industrial Control Equipment