

Demko Certificate

Product: Electrical emergency stop device
Manufacturer: Apem Component Ltd., Wellington Street, Thame, Oxon OX9 3BX, England
Production site: Apem Component Ltd., Wellington Street, Thame, Oxon OX9 3BX, England
Certified by request of: Apem Component Ltd., Wellington Street, Thame, Oxon OX9 3BX, England
Trademark: **APEM**
Model/Type ref.: A0150B and A0154B
Rated current and voltage: AC-15: 1.5 A, 250 V AC
Insulation Class: II
Degree of protection: IP 65
Additional information: I_{ca} : 6 A; U_i : 320 V; U_{imp} : 2.5 kV; CTI 175 V; IP 65; rated short-circuit current: 1 kA; pollution degree: 3; material group: IIIa; mechanical durability: 100 000 cycles

A sample of the product has been tested and found in conformity with the current EN 60947-5-5:1997, EN 60947-5-1:1997 + A1:1999 + A12:1999 + A2:2000 and EN 60947-1:1999 + A1:2000, as shown in the Test Report ref. No. 133402-01.

Furthermore the product complies with the national deviations in Denmark.

Date of expiry: 2012-11-26.


The manufacturer complies with the Production Surveillance Requirements.

UL International Demko A/S is a body notified to the Member States and Commission of the European Communities according to the provisions of Article 8 of the Low Voltage Directive.

Products included in this certificate are allowed to carry the registered approval marks of UL International Demko A/S, ® or for cables <DEMKO>. The name of UL International Demko A/S can be used in the marketing of the products as well.

This certificate is only valid for products, which are identical to the certified product, and manufactured at the above-mentioned production site(s). UL International Demko A/S has to be informed in writing about any changes, in accordance with the "UL International Demko A/S Standard Terms and Conditions" for UL International Demko A/S services. This document contains 1 page(s).

Herlev, 2002-11-26


Karina Christiansen
Certification Manager

UL International Demko A/S

Lyskaer 3, P.O. Box 514
DK-2730, Herlev, Denmark
Telephone: +45 44856563
Fax: +45 44856500



A Subsidiary of
**Underwriters
Laboratories Inc.**