



CERTIFICATE OF APPROVAL

ISSUED PURSUANT TO SECTION 21C OF THE ELECTRICITY SAFETY ACT 1945

ISSUED TO:

Access Communications Pty Ltd

CLASS OF ARTICLE:

Supply Flexible Cord

DESCRIPTION OF ARTICLE:

Supply Flexible Cord
(Three-core, 1.00mm², PVC insulated and sheathed ordinary duty circular flexible cord with untinned copper conductors)
Trade Name: 'Powermaster or Access'
300/500V

EXAMINED FOR COMPLIANCE WITH: AS/NZS 3191 : 1996 A1-2

TYPE REFERENCE CODE: Cat No. GD-3 3X1.0 sq mm

APPROVAL MARK:

Each electrical article of the abovementioned type shall be marked with Approval Number N18155

DATE OF APPROVAL: 14 November 2001

This approval expires 14 November 2006 unless suspended, cancelled, renewed or extended.


for **DIRECTOR-GENERAL**



DEPARTMENT OF **FAIR TRADING**
NSW Consumer Protection Agency

ADDENDUM TO CERTIFICATE OF APPROVAL No 18155

Particulars of Modification(s)

- (a) Cat No. GD-3 3X0.75 sq mm being similar to original Cat No. GD-3 3X1.0 sq mm except for a change in conductor size from 1.0 sq mm to 0.75 sq mm.
- (b) Cat No. GD-2 2X1.0 sq mm being similar to original Cat No. GD-3 3X1.0 sq mm except two-core in lieu of three-core.
- (c) Cat No. GD-2 2X0.75 sq mm being similar to modification Cat No. GD-3 3X0.75 sq mm except two-core in lieu of three-core.
- (d) Cat No. LD-3 3X0.75 sq mm being similar to modification Cat No. GD-3 3X0.75 sq mm except for:-
 - (i) Light duty in lieu of ordinary duty; and
 - (ii) A voltage rating of 300/300V in lieu of 300/500V.
- (e) Cat No. LD-2 2X0.75 sq mm being similar to modification Cat No. LD-3 3X0.75 sq mm except two-core in lieu of three-core..
- (f) Cat No. LD-2F 2X0.75 sq mm being similar to modification Cat No. LD-2 2X0.75 sq mm except for flat in lieu of circular construction.
- (g) Cat No. GD-2F 2X0.75 sq mm being similar to modification Cat No. GD-2 2X0.75 sq mm except flat in lieu of circular construction.

Approved: 14 November 2001


for DIRECTOR-GENERAL

Ref: 18155/2


RENEWAL OF CERTIFICATE OF APPROVAL 18155

PARTICULARS OF RENEWAL

The approval of the original supply flexible cord Cat. No. GD-3 3x1.00mm² and approved modifications has been renewed for a period of FIVE (5) years

Date of Renewal: 12 September 2006

The Approval expires on 14 November 2011 unless it is renewed, extended, suspended or cancelled.



for Commissioner for Fair Trading