



Certificate of Compliance

Item Tested: Pre-production samples of a 13A unswitched fused connection unit with an incorporated residual current device, rated at 230V, 13A, with a rated tripping current of 30mA

Model: K92
(your catalogue part H92).

No. of Samples Tested: 32 samples

Relevant Specification used as Basis of Tests: BS 5733 : 1995 (Amd 1) and relevant parts of BS 7288 : 1990 (Amd 1)


This is to certify that, on the basis of the tests undertaken, the samples of the above item are considered to comply with the above standard.

Signed: N. A. Jones
N A Jones
Certifying Officer

Date of test: 11 September 2001
Date of issue: 9 October 2001



PBT Ltd
1 Astra Centre
Edinburgh Way
Essex
CM20 2BN



Serial No: 17196
Report No: 01005474/Issue 1